


ANEMOSTAT[®]

AIR TERMINAL CONTROLS

Control Package BR - A - 5204

- BYPASS / RELIEF
- ANALOG ELECTRONIC CONTROLS
- VAV COOLING
- MODULATING (0-10 VDC) HOT WATER REHEAT
- PRESSURE DEPENDENT
- ADJUSTMENTS AT THERMOSTAT

DAMPER ROTATION	
RIGHT HAND CONTROLS	LEFT HAND CONTROLS
CW = OPEN	CW = CLOSE
CCW = CLOSE	CCW = OPEN



JOB NAME:
SUBMITTED BY:
DATE:

DWG #: BR-A-5204
REV: -
DATE: 4-4-14