


# ANEMOSTAT®

## AIR TERMINAL CONTROLS

Control Package  
**SD - P - 3120**

- SINGLE DUCT
- VAV COOLING
- PRESSURE INDEPENDENT
- PNEUMATIC CONTROLS
- DIRECT ACTING THERMOSTAT
- NORMALLY OPEN DAMPER
- EARLY MORNING WARM-UP (MAIN AIR PRESSURE SWITCHING)
- OPTIONAL HOT WATER REHEAT



————— FACTORY PIPING  
- - - - - FIELD PIPING

REFER TO ANEMOSTAT "CONTROLS MANUAL" (CM-1) FOR ADJUSTMENT & TROUBLESHOOTING PROCEDURES.

JOB NAME:  
SUBMITTED BY:  
DATE:

DWG #: SD-P-3120.1  
REV: -  
DATE: 12-6-12