


ANEMOSTAT[®]

AIR TERMINAL CONTROLS

Control Package
SD - P - 3175

- SINGLE DUCT
- VAV COOLING
- PRESSURE INDEPENDENT
- PNEUMATIC CONTROLS
- DIRECT ACTING THERMOSTAT
- NORMALLY OPEN DAMPER
- DUAL MINIMUM (REHEAT)
- OPTIONAL HOT WATER REHEAT



————— FACTORY PIPING
- - - - - FIELD PIPING

REFER TO ANEMOSTAT "CONTROLS MANUAL" (CM-1) FOR ADJUSTMENT & TROUBLESHOOTING PROCEDURES.

JOB NAME:
SUBMITTED BY:
DATE:

DWG #: SD-P-3175.1
REV: -
DATE: 12-5-12