


# ANEMOSTAT<sup>®</sup>

## AIR TERMINAL CONTROLS

Control Package  
**SD - P - 3420**

- SINGLE DUCT
- VAV COOLING
- PRESSURE INDEPENDENT
- PNEUMATIC CONTROLS
- REVERSE ACTING THERMOSTAT
- NORMALLY CLOSE DAMPER
- EARLY MORNING WARM-UP (MAIN AIR PRESSURE SWITCHING)
- OPTIONAL HOT WATER REHEAT



— FACTORY PIPING  
- - - FIELD PIPING

REFER TO ANEMOSTAT "CONTROLS MANUAL" (CM-1) FOR ADJUSTMENT & TROUBLESHOOTING PROCEDURES.

JOB NAME:  
SUBMITTED BY:  
DATE:

DWG #: SD-P-3420.1  
REV: -  
DATE: 12-6-12