

S-VENT[®]

SUBMITTAL SHEET



1220 WATSONCENTER ROAD • CARSON, CA 90745-4206
(310) 835-7500 • FAX (310) 835-0448
e-mail: airsec@anemostat.com • website: www.anemostat-hvac.com

SV2-_-ZB


SPECIFY TYPE

MAXIMUM SECURITY GRILLE


1/8" X 1/8" OPENING
with

FACE MOUNTED Z-BRACKET


TOP SECTION




SIDE SECTION



FRONT SECTION



FRONT SECTION
without GRILLE, with OBD



PRODUCT FEATURES

Face Flange

☐ 12 GA (standard)

Material Type

☐ Cold Rolled Steel (standard)

Horizontal/Vertical Mullions

☐ 12 GA with 1 7/16" Neck Depth (std)

Duct Collar

☐ 14 GA (standard)

Opposed Blade Damper (optional)
(shipped loose)

☐ Front Operated

☐ Rear Operated

Coupling Nuts with Threaded Rods

☐ (standard)

Finish

☐ White Powder Coat (std)

☐ Other Powder Coat Colors _____

Z-Bracket for Wall Mount

☐ Aligns with Rear Mounting Bracket

IMPORTANT: It is the specifier's responsibility to properly configure the HVAC system to meet the appropriate level of comfort, safety, security and detention

MUST SPECIFY TYPE (BASED ON ROUGH OPENING SIZE)
AS PART OF MODEL NUMBER WHEN PLACING ORDER

ROUGH OPENING SIZES (WIDTH X HEIGHT)

Dimensions in Inches		WIDTH								
		6.4	8.4	10.4	12.4	14.4	16.4	18.4	20.4	22.4
HEIGHT	6.1	A1	B1	C1	D1	E1	F1	G1	H1	J1
	8.1	A2	B2	C2	D2	E2	F2	G2	H2	J2
	10.1	A3	B3	C3	D3	E3	F3	G3	H3	J3
	12.1	A4	B4	C4	D4	E4	F4	G4	H4	J4
	14.1	A5	B5	C5	D5	E5	F5	G5	H5	J5
	16.1	A6	B6	C6	D6	E6	F6	G6	H6	J6
	18.1	A7	B7	C7	D7	E7	F7	G7	H7	J7
	20.1	A8	B8	C8	D8	E8	F8	G8	H8	J8
	22.1	A9	B9	C9	D9	E9	F9	G9	H9	J9

QTY	TYPE	ROUGH OPENING		WALL
		W"	X H"	DEPTH
27	C4	10.3	12.1	6"

SUBMITTAL APPROVAL

Job Name and Location			
Engineer	Date	Factory	Date
Mfr. Rep.	Date	Submitted By	Date