

S-VENT[®]


SUBMITTAL SHEET



1220 WATSONCENTER ROAD • CARSON, CA 90745-4206
 (310) 835-7500 • FAX (310) 835-0448
 e-mail: airsec@anemostat.com • website: www.anemostat-hvac.com

SSV26-__-ZB

SPECIFY TYPE
MAXIMUM SECURITY GRILLE
 2" (max.) X 3/16" OPENING
 with
 FACE MOUNTED Z-BRACKET



PRODUCT FEATURES

- Face Flange**
 14 GA (standard)
- Material Type**
 Stainless Steel (standard)
- Horizontal/Vertical Mullions**
 14 GA with 1 7/16" Neck Depth (std)
- Duct Collar**
 14 GA Galvanized (standard)
- Opposed Blade Damper (optional)**
 (galvanized, shipped loose)
 Front Operated
 Rear Operated
- Coupling Nuts with Threaded Rods**
 (standard)
- Finish**
 2B Mill Finish (std)
 White Powder Coat (opt)
 Other Powder Coat Colors _____
- Z-Bracket for Wall Mount**
 Aligns with Rear Mounting Bracket

IMPORTANT: It is the specifier's responsibility to properly configure the HVAC system to meet the appropriate level of comfort, safety, security and detention

MUST SPECIFY TYPE (BASED ON ROUGH OPENING SIZE) AS PART OF MODEL NUMBER WHEN PLACING ORDER

ROUGH OPENING SIZES (WIDTH X HEIGHT)

Dimensions in Inches	WIDTH									
	6.4	8.4	10.4	12.4	14.4	16.4	18.4	20.4	22.4	
6.1	A1	B1	C1	D1	E1	F1	G1	H1	J1	
8.1	A2	B2	C2	D2	E2	F2	G2	H2	J2	
10.1	A3	B3	C3	D3	E3	F3	G3	H3	J3	
12.1	A4	B4	C4	D4	E4	F4	G4	H4	J4	
14.1	A5	B5	C5	D5	E5	F5	G5	H5	J5	
16.1	A6	B6	C6	D6	E6	F6	G6	H6	J6	
18.1	A7	B7	C7	D7	E7	F7	G7	H7	J7	
20.1	A8	B8	C8	D8	E8	F8	G8	H8	J8	
22.1	A9	B9	C9	D9	E9	F9	G9	H9	J9	

QTY	TYPE	ROUGH OPENING W" X H"	WALL DEPTH
27	C4	10.3 X 12.1	6"

SUBMITTAL APPROVAL

Job Name and Location			
Engineer	Date	Factory	Date
Mfr. Rep.	Date	Submitted By	Date

MARCH 2015
 NEW CONSTRUCTION
 STAINLESS STEEL