




SUBMITTAL SHEET

LIGATURE RESISTANT GRILLE
3/16" X 3/16" APERTURES

www.anemostat-hvac.com

MAXIMUM SECURITY • FACE MOUNTED Z-BRACKET



IMPORTANT: It is the specifier's responsibility to properly configure the HVAC system to meet the appropriate level of comfort, safety, security and detention

PRODUCT FEATURES

Grille Construction

- Cold Rolled Steel (CRS)
- 14 Gauge Face and Core
- Coupling Nuts with Threaded Rod
- Z-Bracket, Galvanized Steel
- Duct Collar, 14 Gauge Galvanized Steel

Finish

- White Powder Coat (STANDARD)
- Other _____

Options

- Model OB-1 Opposed Blade Damper (**Rear Operated**, Galvzd Steel, Field Installed)
- Model OB-1 Opposed Blade Damper (**Front Operated**, Galvzd Steel, Field Installed) - S-VENT Grille removable for damper adjustment

QTY	Order Size	D Wall Depth

All dimensions are in inches.

JOB NAME:

SUBMITTED BY:



SUBMITTAL SHEET

www.anemostat-hvac.com

LIGATURE RESISTANT GRILLE
3/16" X 3/16" APERTURES


MAXIMUM SECURITY • FACE MOUNTED Z-BRACKET

ORDER SIZE

Order size is based on the table below and determines the rough opening size in the wall. For example, an S-Vent grille Order Size C3 requires a wall rough opening of 10.4" wide x 10.1" high.

		W = WIDTH (ROUGH OPENING)								
		6.4	8.4	10.4	12.4	14.4	16.4	18.4	20.4	22.4
H = HEIGHT (ROUGH OPENING)	6.1	A1	B1	C1	D1	E1	F1	G1	H1	J1
	8.1	A2	B2	C2	D2	E2	F2	G2	H2	J2
	10.1	A3	B3	C3	D3	E3	F3	G3	H3	J3
	12.1	A4	B4	C4	D4	E4	F4	G4	H4	J4
	14.1	A5	B5	C5	D5	E5	F5	G5	H5	J5
	16.1	A6	B6	C6	D6	E6	F6	G6	H6	J6
	18.1	A7	B7	C7	D7	E7	F7	G7	H7	J7
	20.1	A8	B8	C8	D8	E8	F8	G8	H8	J8
	22.1	A9	B9	C9	D9	E9	F9	G9	H9	J9

INSTALLATION (EXPLODED VIEW)



JOB NAME:

SUBMITTED BY: