


SUBMITTAL SHEET




from: **ANEMOSTAT**®

CARSON CA  
310-835-7500

MODEL  
**C-24**

ADJUSTABLE PATTERN  
FLUSH TO CEILING  
EXPOSED DUCTWORK  
PROJECTION HEATING

**Material:** Steel  
**Finish:** White



SIZE	NECK AREA SQ. FT.	O	P	U	W	X	Z
6	.196	7	2-7/8	14-3/4	2-1/4	6	1-13/16
8	.349	9	3	20	2-13/16	8	2-1/16
10	.545	11	3	26-1/2	4-7/16	10	3-1/8
12	.785	13	2-5/8	26-1/2	4-1/2	12	3-1/8
15	1.227	16	3	37-3/4	5-1/8	15	4
18	1.767	19	2-1/2	37-3/4	4-7/8	18	4

NOTE: NECK MOUNTED AIR CONTROL ACCESSORIES WILL INTERFERE WITH THE CENTER PATTERN CONTROL SCREWS & SHOULD BE FIELD INSTALLED IN THE RIGID SUPPLY DUCT UPSTREAM OF THE DIFFUSER.

All Dimensions are in Inches

JOB NAME:	SUBMITTED BY:
LOCATION:	
ARCHITECT:	
ENGINEER:	DWG # CIR-0076
CONTRACTOR:	DATE 1-8-09 REV A