











**Table 14: NC Values – EZTS units with 1/2" Matte Faced Insulation**

Inlet Size	Airflow (CFM)	Radiated Noise Criteria (NC)				Discharge Noise Criteria (NC)			
		ΔPs (in w.g.)				ΔPs (in w.g.)			
		0.5	1.0	2.0	3.0	0.5	1.0	2.0	3.0
<b>5</b>	125	---	---	---	---	---	---	---	---
	175	---	---	21	23	---	---	---	---
	250	---	---	25	27	---	---	21	24
	300	---	21	26	30	---	---	24	26
	350	---	24	29	33	---	20	25	27
<b>6</b>	200	---	---	20	22	---	---	---	---
	250	---	---	22	25	---	---	22	22
	300	---	---	24	27	---	20	26	27
	350	---	---	25	30	---	21	27	31
	400	---	---	26	31	---	23	29	34
	500	---	22	27	32	---	25	32	36
<b>7</b>	250	---	---	22	23	---	---	---	---
	300	---	24	24	26	---	---	21	21
	400	---	25	32	31	---	20	26	27
	500	---	26	36	37	---	21	29	31
	600	20	27	37	40	---	22	30	34
	675	21	29	38	41	---	24	31	35
	<b>8</b>	350	---	---	24	24	---	---	24
475		---	---	30	30	---	---	26	30
600		---	20	31	35	---	20	30	35
700		---	21	32	36	---	22	31	36
800		---	22	34	37	---	22	32	37
900		21	24	35	38	---	24	34	38
<b>9</b>	450	---	20	27	34	---	---	22	24
	525	---	21	29	37	---	---	25	26
	600	---	22	30	38	---	---	26	27
	700	---	24	31	39	---	---	27	31
	900	22	25	32	40	---	20	29	32
	1100	24	26	34	41	---	21	30	35
<b>10</b>	550	---	---	26	31	---	---	26	31
	675	---	20	27	32	---	---	27	32
	800	---	21	29	34	---	20	29	34
	1000	---	22	30	35	---	21	30	35
	1200	20	24	31	36	20	24	31	36
	1400	23	26	32	37	21	25	32	37
<b>12</b>	800	---	---	29	32	---	---	26	31
	1000	---	---	30	33	---	---	27	32
	1200	---	20	31	34	---	---	29	34
	1400	---	21	32	35	---	20	30	35
	1700	---	24	34	36	---	21	31	36
	2000	23	26	35	37	---	24	32	37
<b>14</b>	1050	---	20	30	32	---	---	26	31
	1400	---	21	31	35	---	---	27	32
	1800	---	22	32	36	---	20	29	34
	2200	---	24	34	37	---	21	30	35
	2600	22	26	35	38	---	24	31	36
	3000	25	29	35	39	21	26	32	37
<b>16</b>	1400	---	21	31	35	---	---	26	31
	1900	---	22	32	35	---	---	27	32
	2400	---	24	34	36	---	20	29	34
	2900	20	26	35	38	---	22	30	35
	3500	24	29	36	39	20	25	31	36
	4100	27	31	37	40	24	28	34	38
<b>24x16</b>	3000	24	29	36	39	---	24	31	36
	4000	30	34	40	42	24	27	34	38
	5000	35	39	44	46	30	32	37	40
	6000	39	41	46	49	36	37	40	42
	7000	42	45	49	51	38	39	41	44

**Table 2: AHRI Attenuation Table**

	Octave Band							
	2	3	4	5	6	7		
Radiated	2	1	0	0	0	0	0	Environmental Effect
All Sizes	16	18	20	26	31	36		Type II Mineral Fiber
	<b>18</b>	<b>19</b>	<b>20</b>	<b>26</b>	<b>31</b>	<b>36</b>		<b>Total dB Reduction</b>
	Octave Band							
	2	3	4	5	6	7		
Discharge	2	1	0	0	0	0	0	Environmental Effect
Sizes 5-7	2	4	10	20	20	14		5 ft., Duct Lining (12x12)
(300-700	9	5	2	0	0	0		End Reflection
cfm)	6	10	18	20	21	12		5 ft., 8 in. Flex Duct
	5	6	7	8	9	10		Room Effect
	3	3	3	3	3	3		Sound Power Division
	<b>27</b>	<b>29</b>	<b>40</b>	<b>51</b>	<b>53</b>	<b>39</b>		<b>Total dB Reduction</b>
	Octave Band							
	2	3	4	5	6	7		
Discharge	2	1	0	0	0	0	0	Environmental Effect
Sizes	2	3	9	18	17	12		5 ft., Duct Lining (15x15)
8-24x16	9	5	2	0	0	0		End Reflection
(>700 cfm)	6	10	18	20	21	12		5 ft., 8 in. Flex Duct
	5	6	7	8	9	10		Room Effect
	5	5	5	5	5	5		Sound Power Division
	<b>29</b>	<b>30</b>	<b>41</b>	<b>51</b>	<b>52</b>	<b>39</b>		<b>Total dB Reduction</b>

**Notes:**

1. NC values are calculated based on procedures outlined in AHRI standard 885, appendix E as shown in table 2
2. Where no NC value is shown (---), NC values are less than 20